



COMMUNITY WATER SUPPLY

MBHEDLE COMMUNITY



GIYANI LOCAL SCALE CLIMATE
RESILIENCE PROGRAMME



*Technical designs for Local
Multiple Use Systems.
Mbhedle Community water supply*

March 2023

Acknowledgements

We gratefully acknowledge the funding and support for the programme entitled Adaptive response and local scale adaptation for improving water security and increasing resilience to climate change in selected communities in Giyani, Limpopo. The programme is funded by the Government of Flanders, managed by the Water Research Commission and implemented by Tsogang Water and Sanitation, Association for Water and Rural Development (AWARD), University of the Western Cape (UWC) and the WRC's TTO Enterprise Development.



DISCLAIMER

The content of this handbook does not necessarily reflect the views and policies of the WRC or its partners, nor does mention of trade names or commercial products constitute endorsement or recommendation for use. The WRC and partners cannot be held liable in any way for the damage, personal harm or any breakdowns stemming from actions related to the contents of this handbook.

March 2023

Table of Contents

Technical designs for Local Multiple Use Systems.....	2
Mbhedle Community water supply	2
Acknowledgements	3
About this Technical Design document	2
Who is the Technical Design document for?	2
What does the Technical Design document contain?	2
How to use the Technical Design Document?	2
Technical Designs for Community Water Supply	3
1 Mbhedle Community Water Supply	4
Water Sources for the GLSCRp project sites	6
<i>Table 2: GLSCRp Water Source for project sites</i>	6
Water source quality for the GLSCRp Project sites	7
Community Water Supply Technical Drawings:	12

The Giyani Local Scale Climate Resilience Programme (GLSCRCP)

The Giyani Local Scale Climate Resilience Programme (GLSCRCP) aims to develop and implement activities that will research, develop and demonstrate climate adaptive responses and solutions for optimising water utilisation in drought-stricken areas. The programme will focus on the Greater Giyani Municipal area within the Mopani district and aims to impact an estimated 5000 beneficiaries over a three-year period in terms of water utilisation, improved water mix, and socio-economic opportunities as responses to climate adaptation. A 2019 WRC study on droughts and adaptation strategies has highlighted risks to reduced productivity, livelihoods and food security, and an increase in vector and water-borne diseases in communities such as Giyani. Ultimately, climate change impacts on water resources in the Giyani area cannot be underestimated.

The programme has three key areas that will support for improving local scale adaptation and resilience in Giyani. They are:

- 1) a strengthened enabling environment whereby local authorities, institutions, communities, traditional authorities and market players are mobilised to improve climate resilience and water utilisation;
- 2) improved energy, ground and surface water solutions developed with communities to optimise and diversify water sources;
- 3) activities that support livelihoods and local economic development opportunities.

The programme will cover a spectrum of rural and rural residential areas in Giyani, working closely with the Mopani District Municipality and the Greater Giyani Local Municipality. Implementation partners include Tsogang Water and Sanitation as the lead on water projects and infrastructure; Association for Water and Rural Development (AWARD) in support of capacity development and stakeholder engagement, University of the Western Cape (UWC) as the water and energy technical partner and the WRC's TTO Enterprise Development arm on social enterprise development supporting local economic development projects.



About this Technical Design document

This Technical Design document consists of a summary of all 9 GLSCR project sites. They are categorizable as Community Water Supply and Agricultural Cooperative projects. Technical designs for the infrastructure interventions at these sites are included with Google Earth images, as available. Detailed Technical Documents are available for each of the project sites as a Project Profile.

Who is the Technical Design document for?

This technical design document is meant for the Water Service Authority, the Mopani District Municipality and the Department of Agriculture as a record of programme interventions at each site.

What does the Technical Design document contain?

In this technical design document, we share important information on the type of interventions for each project site. We also share the technical designs for the infrastructure that was installed at each project site.

How to use the Technical Design Document?

The Water Service Authority will be able to use this technical design document to update their asset register for infrastructure upgrades, to have knowledge on the type of systems and infrastructure installed and how to maintain it. Furthermore, the Water Service Authority will be able to use this document as a point of reference for infrastructure budgeting purposes and to inform their borehole operators, supervisors and water quality technicians. The Community Water Committees will use the document as a point of reference to manage the system and for minor maintenance.

Technical Designs for Community Water Supply

The feasibility and design of the systems at each pilot site was refined in more detail based on the following aspects:

1. The original feasibility study conducted in WRC project No. C2020.2021-00718 (Jovanovic et al., 2021)
2. More specific coordinates, elevations measured at key points during the field campaign on 14-19 May 2022; further discussions with stakeholders that took place during the same field campaign
3. Technical information (static rest water levels and required pressure heads; water requirements pipeline layout, pipe diameter, installation and size of tanks; installation of booster pumps to secure enough water pressure is delivered)

The main method for the refinement of MUS technical design at pilot sites was the adapted Toolbox for Solar Powered Irrigation Systems (SPIS) (GIZ and FAO, 2021) and field measurements. Further refinement is possible once equipment specification and availability on the market from suppliers and manufacturers is known, as well as specific borehole characteristics and pumping tests. In particular, for the drinking water sources, the final work designs will consider the water treatment plant packages and the need for pressure booster pumps for water delivery to the distribution and storage systems. It should be noted that, for all sites, water meters will have to be installed at the point of abstraction and at the point of use, so that the efficiency of the distribution system can be assessed during performance evaluation, e.g. leakages and losses of water.

The following table describe the description and intervention for each community water supply project:

Community Water Supply	Interventions
Mbhedle Community Water Supply	1. Hybrid Solar System installed: This innovation integrates grid-supply with solar power for the purposes of powering local groundwater supply systems. The innovation provides relief from grid load shedding and allows for cheaper access to water for rural villages.
	2. Security of Hybrid Solar System installed: Theft and vandalism can be problematic. The project installed palisade fencing, barbed fencing and alarm systems to protect investments.
	3. Water Storage installed: Water storage provides both pressure for driving reticulated water as well as continued supply when the solar powered pumps are not functioning.
	4. Borehole testing, equipping and skills development: All boreholes where tested for water quality and equipped with a suitable pump for the system. In all cases beneficiaries where trained to understand water quality monitoring procedures.
	5. Animal Drinking trough refurbished: This is a vital structure designed to provide water to livestock and other farm animals. It is

	an essential component in agricultural settings, ensuring that animals have access to clean and fresh water, which is crucial for their health, growth, and productivity.
	6. Water Treatment system installed: This system is a compact, often portable, setup designed to purify and treat water for specific needs such as household use, agricultural purposes, or small-scale industrial applications. These systems are ideal for providing safe, clean water in environments where larger infrastructure may not be feasible or necessary.

Table 1: Community Water Supply project sites and GLSCR intervention

1 Mbhedle Community Water Supply

BACKGROUND

Mbhedle village has a population of 1,230 requiring 30.8 m³ d⁻¹ or 11,242 m³ a⁻¹ (calculated as 25 L/person d⁻¹). There is no bulk water supply and the villagers have to walk at least 0.7 km to collect water. The currently operating borehole No. WAR15050 was proposed by the community as water source.

INTERVENTION CONTENT

Solar panels plus electricity hybrid system, a water treatment plant and a storage tank for drinking water supply and livestock were installed at the community. The pump and accompanying solar panels array are installed at borehole WAR15050, which is located outside the village in a low-lying draining dip (elevation is 400 m). The water treatment is essential given the elevated electrical conductivity, predominantly NaCl, NO₃, TOC and Mn in the borehole water. A small reverse osmosis plant requires a pressure of 3 b (30 m) and it will consume 3-10 kWh of energy per m³ of water purified. It is uncertain whether these requirements can be satisfied by solar panels; it will depend on the supplier/manufacturer of the system. Therefore, a hybrid power supply system may be required. From there, a booster pump will likely be required to convey water through a 75 mm main pipeline to an elevated steel reservoir (200 m³, 10 m high) in the centre of the village. The location of the reservoir was recommended by the community and it is at 418 m elevation. Some earth works were required to convey the main pipeline from the abstraction point to the centre of the village (1.4 km)




Figure 1: Final installation scheme of solar powered groundwater pumps for drinking water supply at Mbedle Village (background is Google Earth image)

Water Sources for the GLSCR project sites

Village	Site	Water requirements		Source of water	Coordinates		Duration	Purpose
		(m ³ d ⁻¹)	(m ³ a ⁻¹)		Latitude	Longitude		
Mbhedle	Village population = 1230	30.8*	11242	Borehole in village, not recorded	-	-	3 years	Drinking water. No bulk water supply, villagers have to walk up to 0.7 km to collect water. Site proposed by community members.
Mayephu	Village population = 1940	48.5*	17702.5	Borehole No. H14-1815	-23.589623°	30.778480°	3 years	Drinking water. Emergency intervention linked to bulk water supply. Borehole and reservoir are established.
				Borehole No. H14-1818	-	-		
Mzilela	Village population = 1150	28.8*	14162	Borehole in village	-23.592869°	30.17120°	3 years	Drinking water. Bulk water supply is seldom available due to water shortage (once per month).
Matsotsosela	Village population = 2300	57.5*	20987.5	Borehole No. H14-0026	-23.60106°	30.829530°	3 years	Drinking water. No bulk water supply. Boreholes are established. Diesel expenses subsidized by local government are extremely high. Community operator is very committed.
				Borehole No. H14-0025	-23.600749°	30.825683°		
Dzumeri	Nhlambeto farm	58.9**	21863.5	Non-perennial river sand	-23.561512°	30.701696°	3 years	Drinking water + emerging farm. Emerging farmer was recently asked to stop farming by other water users due to drop in groundwater level.
Dzumeri	Ngamba farm	33.9	12373.5	Borehole not numbered	-23.591533°	30.706566°	3 years	Emerging farm. Pressure head is too low with the current pumping system.
Dzumeri (Daniel Ravalela)	A hi tirheni Mqekwa farm	33.9	12373.5	Borehole No. H14-1699	-23.57025°	30.65841°	3 years	Emerging farm. Well established. Electricity bills are very high.
				Borehole No. H14-1700	-23.57094°	30.65878°		
Loloka	Duvadzi farm	33.9	12373.5	Borehole No. H14-1703	-23.56712°	30.81966°	3 years	Emerging farm. Well established. Groundwater can also be abstracted from adjacent non-perennial river sand.
Muyexe	Muyexe community project	33.9	12373.5	Borehole not numbered	-23.187820°	30.911963°	3 years	Emerging farm. Rehabilitation of cooperative by Limpopo Department of Agriculture is planned.

Table 2: GLSCR Water Source for project sites

Water source quality for the GLSCR Project sites

Groundwater samples were collected during a field campaign on 26-31 October 2022 and collection of the samples is a continuous process in all the water sources. The samples were collected at the water sources according to standard procedures in 0.25 L plastic bottles, for chemical analyses in the laboratory. Water sources at all 9 pilot sites were sampled, except at Matsotsosela where borehole H14-0025 dried up and the pump at the currently operating borehole H14-1724 could not be started. The samples were kept in a cooler box with ice bricks, and sent to the Central Analytical Facility (CAF) of Stellenbosch University for laboratory analyses. The following physical and chemical parameters were analysed:

- Physical parameters: electrical conductivity (EC), total dissolved solids (TDS) and colour (Hazen)
- pH and total organic carbon (TOC)
- Anions: F, Cl, SO₄, NO₂, NO₃, Br
- Cations: Li, Na, Ca, Mg, K, NH₄
- Heavy metals: Al, Mn, Fe, Cu, Cd, Zn

All the results are presented in the tables below and they were compared to the South African National Standard SANS 241 of 2015 to determine the water quality fitness for domestic use. The figures in red in the tables indicates values of determinants that are not within the SANS 241 thresholds. For comparative purposes, the analyses of samples collected in the previous sampling campaign on 14-19 May 2022 are shown in the tables.

Although the pH values were within the range of drinking water quality standards for all sites, high salinity levels (Electrical Conductivity EC and Total Dissolved Solids TDS) were recorded at Mbhedle, A hi tirheni Mqekwa and Duvadzi, mainly due to elevated Na and Cl. High NO₃ levels were recorded at Mbhedle, Mayephu, Mzilela (borehole H14-0022), A hi tirheni Mqekwa and Muyexe, above the legally required standard for drinking water quality (<48.7 Mg L⁻¹ NO₃). The borehole at Mbhedle also displayed elevated NO₂ (6.698 mg/L). Total Organic Carbon (TOC) levels were within the standard drinking water quality range.

In comparison with the previous sampling campaign in May 2022, the elevated salinity values at Mbhedle, A hi tirheni Mqekwa farm and Duvadzi farm were confirmed. The elevated NO₃ at Mbhedle, Mayephu (borehole H14-1815), Mzilela, A hi tirheni Mqekwa and Muyexe were also confirmed due to the proximity of villages (draining water from villages). The spike of 205 mg L⁻¹ NO₃ concentration at borehole H14-1815 in Mayephu was confirmed due to the vicinity of an animal kraal. By far the best water quality source is the water retained in the sand alluvial aquifer of the Molototsi River (Nhlabeto farm at Dzumeri). This confirms previous results from the previous sampling campaign in May 2022. All parameters were within the standard limits, including colour. In general, the findings confirmed the need for groundwater treatment at sources for drinking water purpose. For agricultural purposes, water quality is fit to marginally fit for water use. The risk of salinization should be monitored at all sites.

Analysis	Mbhedle	Mayephu H14-1815	Mzilela H14-0022	Nhlambeto farm	Ngamba farm	A hi tirheni Mqekwa farm H14-1700	Duvadzi farm H14-1702	Muyexe farm	SANS 241
EC (µS/cm) (25°C)	2455	1586	1096	196	1533	2683	3556	1053	≤ 1700
pH (25°C)	7.53	7.06	7.07	7.92	7.01	7.21	7.36	7.54	≥ 5 and ≤ 9.7
TDS (ppm) @ 25°C	1228	793	548	98	767	1342	1778	527	≤ 1200
Colour (Hazen)	0.3	0.0	0.0	6.3	0.0	0.0	0.0	0.0	< 15
F (mg/L)	0.439	0.435	0.205	0.141	0.452	0.443	0.678	0.232	≤ 1.5
Cl (mg/L)	472.705	128.466	117.984	6.497	277.122	668.842	1026.835	62.029	≤ 300
SO ₄ (mg/L)	44.114	71.668	29.832	3.544	28.093	46.311	83.111	24.966	≤ 500 (health) ≤ 250 (aesthetic)
PO ₄ (mg/L)	n.d	n.d	n.d	Below calibration standard	Below calibration standard	n.d	Below calibration standard	Below calibration standard	-
NO ₂ (mg/L)	6.698	n.d	n.d	n.d	n.d	n.d	n.d	n.d	≤ 2.96
Br (mg/L)	1.264	0.627	0.448	Below calibration standard	0.609	1.387	2.611	0.313	-
NO ₃ (mg/L)	62.825	204.651	100.388	4.542	24.799	73.812	27.22	74.728	≤ 48.7
Li (mg/L)	0.025	0.012	0.003	n.d.	0.009	0.026	0.018	Below calibration standard	-
Na (mg/L)	359.952	77.172	72.004	12.883	153.405	242.848	338.291	46.093	≤ 200
NH ₄ (mg/L)	n.d.	n.d.	n.d.	n.d.	n.d.	n.d.	n.d.	n.d.	≤ 1.5
K (mg/L)	11.663	1.269	1.435	1.926	2.393	2.771	11.425	0.583	-
Mg (mg/L)	90.863	101.797	53.733	3.617	74.068	129.812	182.351	71.137	-
Ca (mg/L)	81.935	135.446	67.533	9.435	87.14	164.636	176.275	63.648	-

Table 3: Results of the laboratory analyses of groundwater samples collected from all water sources at the pilot sites on 26-31 October 2022

Analysis	Mbhedle	Mayephu H14-1816	Mayephu H14-1815	Mzilela	Matsotsosela	Nhlambeto farm	Ngamba farm	A hi tirheni Mqekwa farm H14-1700	Duvadzi farm H14-1702	Muyexe farm	SANS 241
EC (µS/cm) (25°C)	2500	1286	1566	1046	2032	279.7	2691	2672	1941	1045	≤ 1700
pH (25°C)	7.286	7.171	6.958	7.928	7.335	7.275	6.857	7.16	7.569	7.768	≥ 5 and ≤ 9.7
TDS (ppm) @ 25°C	1336	523	1016	1250	783	140	643	971	1346	523	≤ 1200
Colour (Hazen)	1.7	1.4	0	0.1	3.3	69.5	1.7	0	0.2	0	< 15
F (mg/L)	0.592	0.598	0.582	0.300	0.968	0.14	0.547	0.596	1.017	0.321	≤ 1.5
Cl (mg/L)	475.706	110.216	125.116	87.419	319.65	16.741	678.633	632.826	463.861	61.275	≤ 300
SO ₄ (mg/L)	44.819	46.085	74.881	31.299	34.524	4.674	36.347	46.188	40.470	24.318	≤ 500 (health) ≤ 250 (aesthetic)
PO ₄ (mg/L)	n.d	<LCS	n.d	n.d	n.d	<LCS	n.d	n.d	n.d	n.d	-
NO ₂ (mg/L)	n.d	.	n.d	n.d	.	n.d	.	n.d	n.d	n.d	≤ 2.96
Br (mg/L)	1.303	0.420	0.634	0.427	0.913	0.069	1.408	1.506	1.411	0.302	-
NO ₃ (mg/L)	73.867	32.588	212.745	77.846	34.99	0.531	31.269	68.950	9.428	70.932	≤ 48.7
Na (mg/L)	357.126	69.707	77.438	47.791	335.407	20.154	240.526	217.145	211.894	49.142	≤ 200
NH ₄ (mg/L)	n.d.	n.d.	n.d.	n.d.	n.d.	n.d.	n.d.	n.d.	n.d.	n.d.	≤ 1.5
K (mg/L)	12.138	2.937	1.984	2.289	4.057	3.797	6.909	6.048	9.253	1.407	-
Mg (mg/L)	93.167	84.701	100.099	85.141	64.826	8.600	133.473	137.232	89.329	79.151	-
Ca (mg/L)	85.097	100.382	137.242	52.957	71.867	20.666	161.796	174.406	93.887	66.138	-
TOC [mg/l]	16.519	15.347	15.533	9.214	15.663	6.629	16.181	15.674	8.467	8.889	≤ 10

Table 4: Results of the laboratory analyses of groundwater samples collected from all water sources at the pilot sites on 15-16 May 2022


Analysis	Nhlambeto farm	Ngamba farm	A hi tirheni Mqekwa farm AHM6	Duvadzi farm H14-1702	Muyexe farm	SANS 241
EC (µS/cm) (25°C)	770	3044	991.8	2136	1054	≤ 1700
pH (25°C)	7.144	6.528	7.588	7.288	6.954	≥ 5 and ≤ 9.7
TDS (ppm) @ 25°C	385	1522	495.9	1068	527	≤ 1200
Colour (Hazen)	6.4	0	0	2.8	0.5	< 15
F (mg/L)	0.132	0.574	0.791	1.061	0.356	≤ 1.5
Cl (mg/L)	114.612	876.824	24.54	525.214	66.463	≤ 300
SO ₄ (mg/L)	13.826	45.924	10.852	55.364	24.882	≤ 500 (health) ≤ 250 (aesthetic)
PO ₄ (mg/L)	n.d	n.d	n.d	Below calibration standard	Below calibration standard	-
NO ₂ (mg/L)	n.d	n.d	n.d	n.d	n.d	≤ 2.96
Br (mg/L)	0.297	1.639	0.17	1.466	0.346	-
NO ₃ (mg/L)	2.106	60.464	2.368	16.16	69.526	≤ 48.7
Na (mg/L)	77.242	275.105	138.067	244.152	55.269	≤ 200
NH ₄ (mg/L)	Below calibration standard	n.d	n.d	n.d	n.d	≤ 1.5
K (mg/L)	6.335	11.475	4.998	10.261	1.069	-
Mg (mg/L)	17.697	145.058	33.308	98.492	73.848	-
Ca (mg/L)	45.39	166.91	47.096	95.499	63.524	-
TOC [mg/l]	8.76	13.94	13.89	13.77	12.60	≤ 10
Al (µg/L)	<LOQ	<LOQ	<LOQ	<LOQ	<LOQ	≤ 300
Mn (µg/L)	262.25	115.14	241.80	24.32	<LOQ	≤ 400 (health) ≤ 100 (aesthetic)
Fe (µg/L)	2.98	1.91	3.84	2.68	3.31	≤ 2000 (health) ≤ 300 (aesthetic)


Analysis	Nhlambeto farm	Ngamba farm	A hi tirheni Mqekwa farm AHM6	Duvadzi farm H14-1702	Muyexe farm	SANS 241
Cu (µg/L)	0.75	1.49	1.65	<LOQ	<LOQ	≤ 2000
Cd (µg/L)	<LOQ	0.09	<LOQ	<LOQ	<LOQ	≤ 3
Zn (µg/L)	1.14	2.07	3.67	0.30	30.44	≤ 5000
As (µg/L)	<LOQ	<LOQ	<LOQ	0.20	7.00	≤ 10

Table 5: Results of the laboratory analyses of groundwater samples collected from all water sources at the pilot sites on 4-8 September 2023.


Community Water Supply Technical Drawings:

1. Hybrid Solar System







2. Fencing (Storage and Solar)




3. Water Storage







4. Borehole testing/ Equipping




5. Animal drinking trough




SECTIONAL PLAN VIEW-A-A



SECTIONAL FRONT VIEW-B-B



SECTION-C-C



SECTION-D-D



NOTES		REFERENCE DOCUMENTS										REVISIONS		PROJECT INFORMATION		PROJECT NUMBER	
		1	2	ITEM DESCRIPTION (REV. DATE)				3	4	5	6	7	8	9	10		
												PROJECT NAME		PROJECT NUMBER			
												DRAWING TITLE					
												PANEL MOUNTING STRUCTURE					
		</															

GLSCRP

GIYANI LOCAL SCALE CLIMATE RESILIENCE PROGRAMME



Government
of Flanders



award



UNIVERSITY of the
WESTERN CAPE



GLSCRP is a community advised and LED programme demonstrating climate adaptive responses and solutions for improved water utilisation in the Giyani Municipal area. It is a partnership programme funded by the Government of Flanders, led by the Water Research Commission with partners Tsogang Water and Sanitation (Tsogang), Association for Water and Rural Development (AWARD) and the University of the Western Cape (UWC). The Programme aims to develop, research and demonstrate, practical water-linked climate adaptation solutions at local, community and catchment scale for the benefit of 5000 Giyani community members in order to improve water utilisation, community resilience and local economic growth for local and women-led enterprises.